

DIRECTORATE OF FIRE SERVICES HIMACHAL PRADESH SHIMLA-2

No. HOM (FS) (HQ) 6-10/76-XL -Sml. NOC dated

Shimla-2

TO WHOM IT MAY CONCERN

22/6/2018

That the premises of Loreto Convent School (Gonzaga Block) Tara Hall, Shimla-3, Distt. Shimla was inspected on 30-05-2018 with reference to their application No. Nil dated 20-04-2018 by the Sub Fire Officer, Fire Station Mall Road Shimla with regard to measures adopted for protection against fire and it has been reported/recommended.

That the First Aid Fire Fighting measures adopted by the above applicant at his premises were found satisfactory at the time of inspection. Hence, No Objection Certificate is issued/ renewed for two years (i.e. 21-06-2018 to 20-06-2020) subject to fulfillment of the following conditions:-

1. That each individual working on the above premises must be trained to handle/operate fire fighting equipment/ system installed therein.
2. That it shall be the responsibility of the above named applicant to maintain the fire fighting equipment/ system in perfect running condition, failing which this certificate shall be treated as cancelled.
3. Mock Drill shall be conducted in accordance with fire safety plan atleast once in every three months and written record shall be kept in the premises for the inspection of fire service.

Remarks: Adequate Fire precautionary measures be adopted in consultation with the local Fire Officer during annual day function or any other function in the school where temporary structures and Pandals are to be erected.

*A. Sharma*  
Chief Fire Officer,  
Himachal Pradesh Shimla-2

To,  
The Principal,  
Loreto Convent School (Gonzaga Block) Tara Hall,  
Shimla-3, Distt. Shimla H.P.